

Facility Summary in RICHLAND County in the City of FAIRVIEW

Location: HORIZON RESOURCES FAIRVIEW STORE
605 S ELLERY AVE
FAIRVIEW, MT 59221 RICHLAND

Sys Fac ID: 42-03363
Last Inspected On: 3/28/2014
Operating Permit Renewal Date: 7/24/2017

Contact: Darcy Yabon, (406) 742-5273

Owners/Operators: Horizon Resources, Owner (701)-572-2172 317 2ND ST W
WILLISTON ND 58011

Ronald Rolle, UST Class A Operator
Darcie Yadon, UST Class A Operator
Ronald Rolle, UST Class B Operator
Darcie Yadon, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
7	17	12/1/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3722			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/31/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
7,800		8/5/2009	TLS-450 , Veeder Root	Continuous Interstitial Monitor	
8	17	12/1/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3723			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		1/31/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,200		8/5/2009	TLS-450 , Veeder Root	Continuous Interstitial Monitor	
9	17	12/1/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3724			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		1/31/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
5,500		8/5/2009	TLS-450 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in RICHLAND County in the City of FAIRVIEW

Location: HORIZON RESOURCES FAIRVIEW STORE
605 S ELLERY AVE
FAIRVIEW, MT 59221 RICHLAND

Contact: Darcy Yabon, (406) 742-5273

Sys Fac ID: 42-03363
Last Inspected On: 3/28/2014
Operating Permit Renewal Date: 7/24/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
10	17	12/1/1998	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
3725			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		1/31/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
4,500		8/5/2009	TLS-450 , Veeder Root	Continuous Interstitial Monitor	
15	05	1/2/2011	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5274			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
10,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes
16	05	1/2/2011	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5275			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
10,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in RICHLAND County in the City of FAIRVIEW

Location: LOAF & JUG 714
516 S ELLERY AVE
FAIRVIEW, MT 59221 RICHLAND

Sys Fac ID: 42-03914
Last Inspected On: 12/2/2013
Operating Permit Renewal Date: 2/25/2017

Contact: Billie Martin, (406) 747-5024

Owners/Operators: Mini Mart Inc Pueblo, Owner (719)-948-3071 442 KEELER PKWY
PUEBLO CO 81001-4813

Randal Liebnow, UST Class A Operator
John Sumowski, UST Class A Operator
Derrick Trimble, UST Class A Operator
Richie Lesser, UST Class B Operator
Billie Martin, UST Class B Operator
Timothy Osterman, UST Class B Operator
Stevie Ulstad, UST Class B Operator
CARL WATKINS, UST Class B Operator
Norma Carlson, UST Class B Global Operator
Randal Liebnow, UST Class B Global Operator
Anthony Mosmiller, UST Class B Global Operator
Toni Mullen, UST Class B Global Operator
Hiede Richardson, UST Class B Global Operator
Derrick Trimble, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	02	3/1/2013	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5410			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
20,000				Not Listed	Yes

Facility Summary in RICHLAND County in the City of FAIRVIEW

Location: LOAF & JUG 714
516 S ELLERY AVE
FAIRVIEW, MT 59221 RICHLAND

Sys Fac ID: 42-03914
Last Inspected On: 12/2/2013
Operating Permit Renewal Date: 2/25/2017

Contact: Billie Martin, (406) 747-5024

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
7	02	3/1/2013	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5411			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
10,000				Not Listed	Yes
8	02	3/1/2013	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5412			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.1, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
8,000				Not Listed	Yes

Facility Summary in RICHLAND County in the City of LAMBERT

Location: NORTANA GRAIN CO
100 1ST AVE SW
LAMBERT, MT 59243 RICHLAND

Sys Fac ID: 42-00317
Last Inspected On: 10/27/2015

Operating Permit Renewal Date: 3/4/2019

Contact: Sheldon Heringer, (406) 774-3331

Owners/Operators: Nortana Grain Co, Owner (406)-774-3331 PO BOX 177
LAMBERT MT 59243-0177
Shane Keller, UST Class A Operator
Shane Keller, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	06	3/6/2009	Concrete	Flexible Plastic	
5201	Yes		None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Gasoline			Deferred	MLLD Line Tightness Testing	
21,000		4/9/2015		Continuous Interstitial Monitor	
6	06	3/6/2009	Concrete	Flexible Plastic	
5202	Yes		None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
21,000		4/9/2015		Continuous Interstitial Monitor	
7	06	3/6/2009	Concrete	Flexible Plastic	
5203	Yes		None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
13,000		4/9/2015		Continuous Interstitial Monitor	
8	06	3/6/2009	Concrete	Flexible Plastic	
5204	Yes		None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
15,000		4/9/2015		Continuous Interstitial Monitor	

Facility Summary in RICHLAND County in the City of LAMBERT

Location: NORTANA GRAIN CO
100 1ST AVE SW
LAMBERT, MT 59243 RICHLAND

Sys Fac ID: 42-00317

Last Inspected On: 10/27/2015

Operating Permit Renewal Date: 3/4/2019

Contact: Sheldon Heringer, (406) 774-3331

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
9	06	3/6/2009	Concrete	Flexible Plastic	
5205	Yes		None	Double-Walled	Yes
Currently in Use			Mechanical Line Leak Detector	Pressurized	Not Applicable
Diesel			Deferred	MLLD Line Tightness Testing	
21,000		4/9/2015		Continuous Interstitial Monitor	

Facility Summary in RICHLAND County in the City of SAVAGE

Location: VALLEY FUEL SUPPLY
MT HIGHWAY 16
SAVAGE, MT 59262 RICHLAND
Contact: Myron Smith, (406) 776-2354

Sys Fac ID: 42-03815
Last Inspected On: 12/30/2014
Operating Permit Renewal Date: 3/14/2018

Owners/Operators: Gregory Cross, Owner (406)-252-5519 CROSS PETROLEUM SERVICE INC
PO BOX 1078
BILLINGS MT 59103-1078

Gregory Cross, UST Class A Operator
Timothy Fife, UST Class A Operator
RJ Serpe, UST Class A Operator
RJ Serpe, UST Class B Global Operator
Ron Serpe, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	17	8/25/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
780			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/18/2008	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		12/1/2011	TLS-350/Gilbarco EMC , Veeder Root		
4	17	8/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
781			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/18/2008	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		11/13/2011	TLS-350/Gilbarco EMC , Veeder Root		
5	17	8/1/1998	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
782			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/18/2008	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
3,000		8/9/2011	TLS-350/Gilbarco EMC , Veeder Root		

Facility Summary in RICHLAND County in the City of SIDNEY

Location: LOWER YELLOWSTONE RURAL ELECTRIC ASSOCIATION INC
MT HIGHWAY 16 NW
SIDNEY, MT 59270 RICHLAND

Sys Fac ID: 42-00001

Last Inspected On: 4/29/2015

Operating Permit Renewal Date: 9/29/2018

Contact: Roger Marker, (406) 488-1602

Owners/Operators: Lower Yellowstone Rural Electric Association Inc, Owner (406)-482-1602 PO BOX 1047
SIDNEY MT 59270-1047
Bodrey Kindopp, UST Class A Operator
Mike Eberling, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	22	10/1/1993	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1558			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Gasoline			Manual Interstitial Monitor	Not Listed	
8,000					
6	22	10/1/1993	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
1559			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Manual Interstitial Monitor	Not Listed	
4,000					

Facility Summary in RICHLAND County in the City of SIDNEY

Location: SWELEY OIL INC BULK PLANT
1123 10TH AVE SE
SIDNEY, MT 59270 RICHLAND

Sys Fac ID: 42-00183

Last Inspected On: 1/5/2016

Operating Permit Renewal Date: 2/18/2019

Contact: John Sweley, (406) 433-2508

Owners/Operators: Nortana Grain Co, Owner

(406)-774-3331

PO BOX 177
LAMBERT MT 59243-0177

John Sweley, UST Class A Operator

John Sweley, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	17	6/16/1998	Bare Steel	Flexible Plastic	
2076	Yes	9/27/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Deferred	Continuous Interstitial Monitor	
17,000			ILS-350 , Veeder Root		
5	17	6/16/1998	Bare Steel	Flexible Plastic	
2077	Yes	9/27/2012	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Deferred	Continuous Interstitial Monitor	
17,000			ILS-350 , Veeder Root		

Facility Summary in RICHLAND County in the City of SIDNEY

Location: SIDNEY CARDTROL
901 3RD ST NE
SIDNEY, MT 59270 RICHLAND

Sys Fac ID: 42-02184

Last Inspected On: 1/3/2014

Operating Permit Renewal Date: 4/30/2017

Contact: James Steffen, (406) 482-4376

Owners/Operators: Gregory Cross, Owner (406)-252-5519 CROSS PETROLEUM SERVICE INC
PO BOX 1078
BILLINGS MT 59103-1078

Gregory Cross, UST Class A Operator
Timothy Fife, UST Class A Operator
Larry Garman, UST Class A Operator
RJ Serpe, UST Class A Operator
Larry Garman, UST Class B Global Operator
RJ Serpe, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	33	4/17/1982	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
776			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		1/3/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000					
2	33	4/17/1982	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
777			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		1/3/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000					
3	33	4/17/1982	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
778			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/3/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000					

Facility Summary in RICHLAND County in the City of SIDNEY

Location: SIDNEY CARDTROL
901 3RD ST NE
SIDNEY, MT 59270 RICHLAND
Contact: James Steffen, (406) 482-4376

Sys Fac ID: 42-02184
Last Inspected On: 1/3/2014
Operating Permit Renewal Date: 4/30/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	33	4/17/1982	Bare Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
779			Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		1/3/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2	
8,000					

Facility Summary in RICHLAND County in the City of SIDNEY

Location: METZ FUEL & SERVICE
625 S CENTRAL AVE
SIDNEY, MT 59270 RICHLAND

Sys Fac ID: 42-03224

Last Inspected On: 5/15/2015

Operating Permit Renewal Date: 9/29/2018

Contact: Jim Metz, (406) 433-2402

Owners/Operators: Metz Fuel Service Inc, Owner (406)-433-2402 625 S CENTRAL
SIDNEY MT 59270
Jim Metz, Operator (406)-433-2402 625 S CENTRAL AVE
SIDNEY MT 59270
Jim Metz, UST Class A Operator
Timothy Thogersen, UST Class A Operator
Timothy Thogersen, UST Class B Operator
Jim Metz, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
10	24	7/11/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2112		10/11/2012	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Manual Interstitial Monitor	Continuous Interstitial Monitor	
8,000					
11	24	7/11/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2113		10/11/2012	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Manual Interstitial Monitor	Continuous Interstitial Monitor	
8,000					
12	24	7/11/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2111			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Manual Interstitial Monitor	Deferred	
8,000					

Facility Summary in RICHLAND County in the City of SIDNEY

Location: METZ FUEL & SERVICE
625 S CENTRAL AVE
SIDNEY, MT 59270 RICHLAND
Contact: Jim Metz, (406) 433-2402

Sys Fac ID: 42-03224
Last Inspected On: 5/15/2015
Operating Permit Renewal Date: 9/29/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
13	24	7/11/1991	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
2110			Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Diesel			Manual Interstitial Monitor	Deferred	
4,000					

Facility Summary in RICHLAND County in the City of SIDNEY

Location: CENEX HARVEST STATES
1281 S CENTRAL AVE
SIDNEY, MT 59270 RICHLAND

Sys Fac ID: 42-03364

Last Inspected On: 9/21/2015

Operating Permit Renewal Date: 2/11/2019

Contact: Sean Dobbs, (406) 433-1401

Owners/Operators: Cenex Harvest States Sidney, Owner (406)-433-1401 PO BOX 1440
MILES CITY MT 59301
David Corbin, UST Class A Operator
David Corbin, UST Class B Operator
Sean Dodds, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	34	6/25/1981	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
605			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/4/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	
2	34	6/25/1981	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4046			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/4/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	
4	34	6/25/1981	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
602			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
>E15		9/4/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in RICHLAND County in the City of SIDNEY

Location: CENEX HARVEST STATES
1281 S CENTRAL AVE
SIDNEY, MT 59270 RICHLAND
Contact: Sean Dobbs, (406) 433-1401

Sys Fac ID: 42-03364
Last Inspected On: 9/21/2015
Operating Permit Renewal Date: 2/11/2019

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
5	34	6/25/1981	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
603			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		9/4/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	
6	34	6/25/1981	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
604			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		9/4/2013	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000			TLS-450 , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in RICHLAND County in the City of SIDNEY

Location: SIDNEY AIRPORT SERVICE
355 AIRPORT RD PO BOX 355
SIDNEY, MT 59270 RICHLAND

Sys Fac ID: 42-04444

Last Inspected On: 12/17/2015

Operating Permit Renewal Date: 2/12/2019

Contact: Barry Holzworth, (406) 480-2024

Owners/Operators: Sidney Airport Service, Owner (406)-488-4031 PO BOX 355
SIDNEY MT 59270-0355
Barry K Holzworth, UST Class A Operator
TJ Schwartz, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	16	4/1/1999	Steel Clad	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3969			Double-Walled	None	Yes
Currently in Use			Not Required	Safe Suction	Not Applicable
Other			Manual Interstitial Monitor	Deferred	
12,000					

Facility Summary in RICHLAND County in the City of SIDNEY

Location: MINI MART 712
706 S CENTRAL AVE
SIDNEY, MT 59270 RICHLAND

Sys Fac ID: 42-05084

Last Inspected On: 9/5/2013

Operating Permit Renewal Date: 1/15/2017

Contact: Gail Strobe, (406) 482-5647

Owners/Operators: Mini Mart Inc Pueblo, Owner (719)-948-3071 442 KEELER PKWY
PUEBLO CO 81001-4813

Randal Liebnow, UST Class A Operator
Dalinda Rasmussen, UST Class A Operator
John Sumowski, UST Class A Operator
Derrick Trimble, UST Class A Operator
LAWRENCE WOOLARD, UST Class A Operator
Eileen Campbell, UST Class B Operator
Richie Lesser, UST Class B Operator
Mary Norgard, UST Class B Operator
Timothy Osterman, UST Class B Operator
Stevie Ulstad, UST Class B Operator
CARL WATKINS, UST Class B Operator
LAWRENCE WOOLARD, UST Class B Operator
Randal Liebnow, UST Class B Global Operator
Anthony Mosmiller, UST Class B Global Operator
Toni Mullen, UST Class B Global Operator
Dalinda Rasmussen, UST Class B Global Operator
Hiede Richardson, UST Class B Global Operator
Derrick Trimble, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	39	4/24/1976	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4586			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasohol/Ethanol		11/22/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000					

Facility Summary in RICHLAND County in the City of SIDNEY

Location: MINI MART 712
706 S CENTRAL AVE
SIDNEY, MT 59270 RICHLAND

Contact: Gail Strobe, (406) 482-5647

Sys Fac ID: 42-05084
Last Inspected On: 9/5/2013
Operating Permit Renewal Date: 1/15/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	39	4/24/1976	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4587			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasohol/Ethanol		11/22/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
4,000					
3	39	4/24/1976	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4588			Lined Interior/Impressed Current	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		11/22/2011	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
4,000					

Facility Summary in RICHLAND County in the City of SIDNEY

Location: SIDNEY HEALTH CENTER
216 14TH AVE SW
SIDNEY, MT 59270 RICHLAND

Sys Fac ID: 42-06159

Last Inspected On: 5/9/2015

Operating Permit Renewal Date: 9/14/2018

Contact: Dan Schneider, (406) 482-2120

Owners/Operators: Sidney Health Center Inc, Owner (406)-482-2120 216 14TH AVE SW
SIDNEY MT 59270-3519

Mark Delaney, UST Class A Operator

Mark Delaney, UST Class B Operator

Robert Jes, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
2	18	9/1/1997	Steel Clad	Flexible Plastic	Flapper Valve (Auto Shutoff)
700		8/13/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Not Required	U.S. Suction	Not Applicable
Diesel		4/19/2012	Manual Interstitial Monitor	Continuous Interstitial Monitor	
4,000		3/18/2009	ILS-350 , Veeder Root		

Facility Summary in RICHLAND County in the City of SIDNEY

Location: SUPERPUMPER #23 SIDNEY
902 S CENTRAL AVE
SIDNEY, MT 59270 RICHLAND

Sys Fac ID: 42-09718

Last Inspected On: 8/28/2013

Operating Permit Renewal Date: 12/31/2016

Contact: Carolyn Hayden, (406) 482-3616

Owners/Operators: SPF Energy Inc, Owner (701)-852-0061 PO BOX 1847
MINOT ND 58702

Shane Farstad, UST Class A Operator
Kristopher J Wolla, UST Class A Operator
Al Erickson, UST Class B Operator
Lory Polensky, UST Class B Operator
Jessica Shaffer, UST Class B Operator
Shane Farstad, UST Class B Global Operator
Greg Schimetz, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	00	11/16/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Positive Shutoff
5595		10/22/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
20,000			TS-550 EVO , Incon	Continuous Interstitial Monitor, Not Listed	Yes
7	00	11/16/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5596		10/22/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
12,000			TS-550 EVO , Incon	Continuous Interstitial Monitor	Yes
8	00	11/16/2015	Fiberglass Reinforced Plastic	Flexible Plastic	Flapper Valve (Auto Shutoff)
5597		10/22/2015	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2	
8,000			TS-550 EVO , Incon	Continuous Interstitial Monitor	Yes

Facility Summary in RICHLAND County in the City of SIDNEY

Location: MILLERS CORNER
2201 W HOLLY ST
SIDNEY, MT 59270 RICHLAND

Sys Fac ID: 56-14071

Last Inspected On: 3/19/2014

Operating Permit Renewal Date: 4/14/2017

Contact: Nitin Patel, (765) 748-9726

Owners/Operators: Millers Corner LLC, Owner (406)-433-4041 324 23RD AVE NW
SIDNEY MT 59270-3579

Gregory Miller, UST Class A Operator
Nitin Patel, UST Class A Operator
Nitin Patel, UST Class B Operator
Gregory Miller, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	13	2/6/2003	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4797			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/19/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
12,000		3/19/2014		Continuous Interstitial Monitor	
2	13	2/6/2003	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4798			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/19/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
8,000		3/19/2014		Continuous Interstitial Monitor	
3	13	2/6/2003	Cathodically Protected Steel	Flexible Plastic	Flapper Valve (Auto Shutoff)
4799			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/19/2014	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
4,000		3/19/2014		Continuous Interstitial Monitor	

Facility Summary in RICHLAND County in the City of SIDNEY

Location: MILLERS CORNER
2201 W HOLLY ST
SIDNEY, MT 59270 RICHLAND

Sys Fac ID: 56-14071

Last Inspected On: 3/19/2014

Operating Permit Renewal Date: 4/14/2017

Contact: Nitin Patel, (765) 748-9726

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	03	8/1/2012	Cathodically Protected Steel	Flexible Plastic	High Level Alarm, Flapper Valve (Auto Shutoff)
5387			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/19/2014	Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
20,000		3/19/2014		Continuous Interstitial Monitor, Not Listed	Yes

Facility Summary in RICHLAND County in the City of SIDNEY

Location: TOWN PUMP OF SIDNEY #3
12280 HWY 200 UNIT 1
SIDNEY, MT 59270 RICHLAND
Contact: Charlie Anderson, (406) 497-6700

Sys Fac ID: 60-15241
Last Inspected On: 12/30/2014
Operating Permit Renewal Date: 1/14/2018

Owners/Operators: Western Catering Services Inc, Owner/Operator (406)-497-6700 PO BOX 6000
BUTTE MT 59702-6000
Trent Biggers, UST Class A Operator
Trent Biggers, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	01	3/1/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5471		7/14/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation	Stat. Inventory Reconciliation	
30,000			TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Not Listed	
2	01	3/1/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5472		7/14/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation	Stat. Inventory Reconciliation	
30,000			TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Not Listed	
3	01	3/1/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5473		7/14/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation	Stat. Inventory Reconciliation	
30,000			TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Not Listed	

Facility Summary in RICHLAND County in the City of SIDNEY

Location: TOWN PUMP OF SIDNEY #3
12280 HWY 200 UNIT 1
SIDNEY, MT 59270 RICHLAND

Contact: Charlie Anderson, (406) 497-6700

Sys Fac ID: 60-15241
Last Inspected On: 12/30/2014
Operating Permit Renewal Date: 1/14/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	01	3/1/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5474		7/14/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation	Stat. Inventory Reconciliation	
30,000			TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Not Listed	
5	01	3/1/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5475		7/14/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation	Stat. Inventory Reconciliation	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Not Listed	
6	01	3/1/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5476		7/14/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation	Stat. Inventory Reconciliation	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Not Listed	
7	01	3/1/2014	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
5477		7/14/2014	Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Stat. Inventory Reconciliation	Stat. Inventory Reconciliation	
20,000			TLS-350/Gilbarco EMC , Veeder Root	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, Not Listed	